



City of Mansfield

Tim Theaker, Mayor

Bureau of Buildings, Inspections, Licenses and Permits

30 N. Diamond Street - Mansfield, OH 44902 – (419)755-9688 Fax-(419)755-9453
www.ci.mansfield.oh.us

AFFIDAVIT OF FUEL GAS LINE TESTING

DATE PERFORMED: _____

COMPANY NAME: _____

CITY CONTRACTOR REGISTRATION NO: _____

PROJECT APPLICATION NO & ADDRESS: _____

Commercial/Non-Residential projects shall be tested in accordance with OMC Section 901.1 (1501.3), which references 2015 IFGC.

Residential projects shall be tested in accordance with RCO Section G2417.

Test Pressure. The test pressure to be used shall be not less than one and one-half times the proposed maximum working pressure, but not less than 3 psig (20 kPa gauge), irrespective of design pressure. Where the test pressure exceeds 125 psig (862 kPa gauge), the test pressure shall not exceed a value that produces a hoop stress in the piping greater than 50 percent of the specified minimum yield strength of the pipe.

Test duration. The test duration shall not be less than 10 minutes.

Test pressure: _____ PSIG

Duration: _____ Minutes

PRINTED NAME OF TESTER: _____

SIGNATURE: _____

CONTACT PHONE NUMBER: _____